

## Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
Guidelines for Canadian Drinking Water Quality							
Admirals Beach	Admiral's Beach	2 Well Fields	Aug 14, 2024	0.20	LTD	LTD	2.10
Appleton	Appleton (+Glenwood)	Gander Lake (The Outflow)	Aug 13, 2024	0.01	0.11	LTD	6.40
Badger	Badger	Well Field, 2 wells on standby	Aug 12, 2024	0.20	LTD	LTD	LTD
Baine Harbour	Baine Harbour	Dug	Sep 09, 2024	0.05	0.22	LTD	LTD
Barachois Brook	Barachois Brook	Drilled	Sep 26, 2024	0.13	0.06	LTD	LTD
Bauline	Bauline	#1 Brook Path Well	Aug 16, 2024	0.05	LTD	LTD	5.80
Bay St. George South	Heatherton	#1 Well Heatherton (Home Hardware)	Sep 13, 2024	2.00	LTD	LTD	1.50
Bay St. George South	Jeffrey's	#1 Well Jeffery's (Joe Curnew)	Sep 13, 2024	0.85	LTD	LTD	0.57
Bay St. George South	Robinson's	#1 Well Robinson's (Louie MacDonald)	Sep 13, 2024	0.20	2.50	LTD	0.60
Bay St. George South	St. Fintan's, St. David's	#1 Well St. Fintan's (The Y)	Sep 13, 2024	0.34	LTD	LTD	0.55
Bay St. George South	Jeffrey's	#2 Well Jeffery's (Calvin Madore)	Sep 13, 2024	1.30	LTD	LTD	0.83
Bay St. George South	St. Fintan's	#2 Well St. Fintan's (Louis King)	Sep 13, 2024	0.26	1.10	LTD	2.40
Bay St. George South	McKay's	#2B Lions Club Well	Sep 13, 2024	0.87	LTD	LTD	0.83
Bay St. George South	Highlands	#3 Brian Pumphrey Well Highlands	Sep 13, 2024	1.90	LTD	LTD	LTD
Bay St. George South	Jeffrey's	#3 Well Jeffery's (Sid Shears)	Sep 13, 2024	3.00	LTD	LTD	1.70
Bay St. George South	Robinson's	#3 Well Robinson's (Gales)	Sep 13, 2024	0.37	LTD	LTD	0.58
Bay St. George South	McKay's	#3 Woodworth Well McKay's	Sep 13, 2024	0.24	LTD	LTD	1.00
Bay St. George South	Lock Leven	#6 Well Loch Leven (Jerry Quilty)	Sep 13, 2024	0.17	0.35	LTD	0.57
Bay St. George South	McKay's	#7 Well McKay's (Gordon Hulan)	Sep 13, 2024	0.50	LTD	LTD	3.00
Bay de Verde	Bay de Verde	Island Pond	Aug 01, 2024	0.01	LTD	LTD	4.30
Bear Cove	Bear Cove	Lower Bear Cove	Sep 10, 2024	0.05	LTD	LTD	5.00
Benoit's Siding	Doyles	# 2 Well Doyles	Sep 23, 2024	1.90	0.05	LTD	1.50
Benoit's Siding	Benoit's Siding (aka Bennett's Siding)	Drilled	Sep 23, 2024	0.87	0.79	LTD	0.74
Birchy Bay	Birchy Bay	Jumper's Pond	Aug 20, 2024	0.03	LTD	LTD	8.20
Bishop's Falls	Bishop's Falls	Northern Arm Lake	Aug 01, 2024	0.01	LTD	LTD	2.20
Black Duck	Black Duck (Siding)	#1 Well	Sep 04, 2024	0.10	0.22	LTD	LTD
Black Duck	Black Duck (Siding)	#2 Well	Sep 17, 2024	0.09	0.11	LTD	LTD
Black Tickle-Domino	Black Tickle-Domino - Outside Tap	Martin's Pond - Tap at Pumphouse	Sep 04, 2024	0.01	0.09	0.01	8.10
Black Tickle-Domino	Black Tickle-Domino - PWDU	Martin's Pond - Tap at Pumphouse	Sep 04, 2024	LTD	LTD	LTD	LTD
Blaketown	Blaketown South	#1 Selby Mercer Well	Aug 06, 2024	0.05	0.97	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland  
and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
				Guidelines for Canadian Drinking Water Quality			
Blaketown	Blaketown	#2 Daphne Pincent Well	Aug 06, 2024	0.08	0.15	LTD	0.68
Blaketown	Blaketown Centre	#3 Fred Osborne Well	Aug 06, 2024	0.06	LTD	LTD	2.00
Blaketown	Blaketown North	#4 Hilda Barrett Well	Aug 06, 2024	0.12	LTD	LTD	0.69
Branch	Branch	Drilled Wells	Sep 26, 2024	0.25	0.43	LTD	LTD
Brent's Cove	Brent's Cove	Paddy's Pond	Sep 05, 2024	0.01	LTD	LTD	12.00
Brigus South	Forge Hill area	#1 Well Forge Hill	Aug 28, 2024	0.37	LTD	LTD	3.20
Brigus South	Near highway	#3 Well Main Road	Aug 28, 2024	0.04	0.10	LTD	0.60
Bryant's Cove	Bryant's Cove South Side	#1 Well - Bert James Well #2 Well - Baxter Bowering Well	Sep 20, 2024	0.06	0.15	LTD	0.90
Bunyan's Cove	Bunyan's Cove	#1 Wellfield	Aug 28, 2024	0.05	0.21	LTD	3.20
Canning's Cove	Upper Canning's Cove	#2 Well - Eugene Ellis	Aug 28, 2024	0.16	0.20	LTD	1.10
Canning's Cove	Centre Canning's Cove	#3 Well - Glenda Penney	Aug 28, 2024	0.12	0.10	LTD	0.54
Cartwright	Cartwright - PWDU	Burdett's Pond	Aug 15, 2024	LTD	LTD	LTD	LTD
Cartwright	Cartwright	Burdett's Pond	Aug 15, 2024	0.01	LTD	LTD	9.20
Cavendish	North Side Cavendish	#1 Well - Max Bishop	Aug 08, 2024	0.23	2.30	LTD	1.00
Cavendish	North Side Cavendish	#2 Well - Tom Critch	Aug 08, 2024	0.23	LTD	LTD	2.60
Chance Cove	Lower Cove	#5B Albert Rowe Well	Aug 02, 2024	0.45	LTD	LTD	1.90
Chance Cove	Upper Cove	Hollett's Well	Aug 02, 2024	LTD	0.13	LTD	1.80
Chance Cove	New Housing Area	New Housing Area Well	Aug 02, 2024	0.57	0.15	LTD	1.40
Chance Cove	Back Cove Area	Olive Smith Well	Aug 02, 2024	0.13	0.26	LTD	0.60
Change Islands	Change Islands - PWDU	#1 Fox Cove Well	Aug 20, 2024	LTD	LTD	LTD	LTD
Channel-Port aux Basques	Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Sep 25, 2024	0.01	0.10	LTD	3.00
Charlottetown (Labrador)	Charlottetown (Labrador)	Middle Pond	Aug 13, 2024	0.01	LTD	LTD	9.20
Charlottetown (Labrador)	Charlottetown (Labrador) - PWDU	Middle Pond	Aug 13, 2024	LTD	LTD	LTD	LTD
Churchill Falls	Churchill Falls	Smallwood Reservoir	Jul 25, 2024	0.01	LTD	LTD	2.80
Clarenville	Clarenville, Shoal Harbour	Shoal Harbour River	Aug 05, 2024	0.02	LTD	LTD	2.20
Clarke's Beach	Otterbury	#2 Well - Delaney Well	Sep 24, 2024	0.10	0.05	LTD	LTD
Colliers	Merrigan's Lane + Main Rd	#2 Well - Merrigan's Well	Sep 24, 2024	0.28	0.38	LTD	0.51
Colliers	Harbour Drive & Main Road	#3 Well - Griffin's Well	Sep 24, 2024	0.18	0.20	LTD	1.20
Colliers	Harbour Drive	#4 Well - Flynn's Well	Sep 24, 2024	0.19	0.22	LTD	LTD
Colliers	Harbour Drive	#5 Well - Whalen's Well	Sep 24, 2024	0.20	0.20	LTD	0.56
Conception Bay South	Conception Bay South	Bay Bulls Big Pond	Sep 12, 2024	0.01	0.06	LTD	1.60
Conception Harbour	Cemetery Road & Main Road	Cemetery Road Well	Sep 23, 2024	0.09	0.46	LTD	0.54

Tap Water Quality for Public Water Supplies in Newfoundland  
and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
				Guidelines for Canadian Drinking Water Quality			
Conception Harbour	Healey's Pond Rd, Old Rd & Main Rd	Healey's Pond Road Well	Sep 23, 2024	0.09	0.09	LTD	LTD
Conception Harbour	Lower Bacon Cove	Lower Bacon Cove Well	Sep 23, 2024	0.67	0.21	LTD	0.61
Conception Harbour	Old Road and Coles Crescent	Old Road Well	Sep 23, 2024	0.24	0.12	LTD	LTD
Conception Harbour	Upper Bacon Cove, Kitchuses	Upper Bacon Cove Well	Sep 23, 2024	0.38	0.09	LTD	0.56
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	Sep 20, 2024	0.01	0.06	LTD	1.50
Cox's Cove	Upper Area	Upper Area Wellfield	Sep 20, 2024	0.52	LTD	LTD	LTD
Eastport	Eastport (+Sandy Cove)	Dug	Aug 05, 2024	0.03	0.33	LTD	0.54
Fermeuse	Fermeuse	Port Kirwan Road Well	Aug 28, 2024	0.14	0.83	LTD	LTD
Flat Bay	Flat Bay (East)	#1 Well	Sep 26, 2024	0.10	LTD	LTD	LTD
Flat Bay	Flat Bay (East)	#3 Well	Sep 26, 2024	0.37	0.90	LTD	0.64
Flat Bay West	Flat Bay West	#3 Well	Sep 26, 2024	0.07	0.94	LTD	LTD
Fleur de Lys	Fleur De Lys	First Pond, Narrow Pond	Sep 04, 2024	0.01	LTD	LTD	9.30
Forteau	Forteau	Trout Brook	Aug 14, 2024	0.03	0.05	LTD	3.40
Frenchman's Cove	Frenchman's Cove	Dug Well	Sep 10, 2024	0.02	0.14	LTD	3.80
Freshwater	Freshwater (Carbonear)	#2 Well - Covage's Lane Well	Sep 24, 2024	0.07	0.15	LTD	0.52
Freshwater	Freshwater (Carbonear)	#3 Well - Wallace Snow Well	Sep 24, 2024	0.44	1.30	LTD	LTD
Gander	Gander	Gander Lake	Aug 13, 2024	0.01	0.16	LTD	4.50
Gaskiers	Gaskiers-Point La Haye - PWDU	Well	Aug 14, 2024	0.01	LTD	LTD	LTD
Georgetown	Georgetown	Drilled	Sep 23, 2024	0.10	0.31	LTD	0.53
Grand Falls-Windsor	Grand Falls-Windsor (+Bishop's Falls, +Wooddale, +Botwood, +Peterview)	Northern Arm Lake	Aug 01, 2024	0.02	LTD	LTD	2.20
Grates Cove	Grates Cove Centre	#1C Well	Aug 01, 2024	0.09	LTD	LTD	0.91
Grates Cove	Grates Cove North End	#3 Frank Janes Well	Aug 01, 2024	0.06	LTD	LTD	1.50
Grates Cove	Grates Cove South End	#4 Stoyles Hill Well	Aug 01, 2024	0.06	0.13	LTD	0.65
Great Codroy	Great Codroy East	#1 Well	Sep 23, 2024	3.10	0.12	LTD	0.52
Great Codroy	Great Codroy West	#2 Well	Sep 23, 2024	0.42	0.09	LTD	0.60
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	Aug 16, 2024	0.02	LTD	LTD	0.73
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Well Field (connect summer 2002)	Aug 16, 2024	0.05	LTD	LTD	0.76
Harbour Grace	Thickett	#1 Thicket Susie Galway Well	Sep 20, 2024	0.05	0.71	LTD	LTD
Harbour Grace	Thickett	#2 Thicket New Well	Sep 20, 2024	0.07	0.34	LTD	LTD
Harbour Grace	Riverhead	Mercer's Rd. Well	Sep 20, 2024	0.03	0.32	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland  
and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
				Guidelines for Canadian Drinking Water Quality			
Harbour Grace	Harbour Grace South Lower	New Southside Well (Well#3)	Sep 20, 2024	0.12	LTD	LTD	LTD
Harbour Grace	Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Sep 20, 2024	0.08	LTD	LTD	LTD
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Flynn's Hill Well	Sep 25, 2024	0.20	0.57	LTD	1.50
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Holden's Road Well	Sep 25, 2024	0.10	0.32	LTD	0.59
Harbour Mille-Little Harbour East	Harbour Mille, Little Harbour East (Fortune Bay)	Well	Sep 12, 2024	0.54	LTD	LTD	10.00
Harry's Harbour	Harry's Harbour	#1C Well - Northeast Well	Sep 16, 2024	0.10	LTD	LTD	0.53
Harry's Harbour	Harry's Harbour	#2 Well - Northwest Hill / Country Road	Sep 16, 2024	0.15	0.11	LTD	1.10
Heart's Content	Heart's Content	Southern Cove Pond	Aug 01, 2024	0.00	LTD	LTD	4.30
Hibbs Cove	Hibbs Cove		Sep 17, 2024	0.43	LTD	LTD	3.90
Hickman's Harbour-Robinson Bight	Hickman's Harbour-Robinson Bight	Big Loss Pound Pond	Jul 11, 2024	0.01	LTD	LTD	4.60
Hickman's Harbour-Robinson Bight	Hickman's Harbour-Robinson Bight	Big Loss Pound Pond	Jul 11, 2024	0.01	LTD	LTD	4.20
Hickman's Harbour-Robinson Bight	Hickman's Harbour-Robinson Bight	Big Loss Pound Pond	Jul 11, 2024	0.01	LTD	LTD	4.80
Holyrood	Holyrood	Main Line	Sep 17, 2024	0.41	LTD	LTD	3.70
Holyrood	Holyrood	Woodford Station - Healey's Well and Quinlan's Well	Sep 17, 2024	0.42	LTD	LTD	3.70
Hopeall	Hopeall	Charles Cumby Well	Aug 08, 2024	0.07	0.30	LTD	0.92
Hopeall	Gilberts Hill	Gilberts Hill Well	Aug 08, 2024	0.10	0.99	LTD	0.95
Hopedale	Hopedale	American Pond	Aug 29, 2024	0.01	LTD	LTD	5.00
Humber Arm South	Frenchman's Cove Area	Gurges Pond	Sep 20, 2024	0.06	LTD	LTD	3.70
Jackson's Cove-Langdon's Cove-Silverdale	Langdon's Cove	#3 Well Langdon's Cove Well	Sep 16, 2024	0.10	LTD	LTD	0.91
Jean de Baie	Jean de Baie	#1 Well	Sep 09, 2024	0.08	0.13	LTD	0.99
Kippens	Kippens	Well Field	Sep 04, 2024	0.10	0.16	LTD	LTD
L'Anse au Clair	L'Anse au Clair	Park Pond	Aug 14, 2024	0.03	0.10	LTD	3.10
L'Anse au Loup	L'Anse au Loup	L'anse Au Loup River	Aug 14, 2024	0.01	0.13	LTD	4.40
Labrador City	Labrador City	Beverly Lake	Jul 24, 2024	0.02	LTD	LTD	2.70
Lewisporte	Lewisporte	Stanhope Pond	Aug 12, 2024	0.02	LTD	LTD	6.40
Mainland	Mainland	Caribou Brook	Sep 17, 2024	0.07	0.30	LTD	1.70
Makinsons	Turkswater & Hodgewater Line West	Country Path Wells	Sep 17, 2024	0.02	0.06	LTD	0.61
Makinsons	Hodgewater Line East & Juniper Stump	Taylor's Wells	Sep 17, 2024	0.54	LTD	LTD	1.70
Makkovik	Makkovik	Ranger Bight Pond	Aug 29, 2024	0.02	LTD	LTD	5.60
Makkovik	Makkovik - PWDU	Ranger Bight Pond	Aug 29, 2024	0.01	0.08	LTD	LTD
Mary's Harbour	Mary's Harbour - PWDU	St. Mary's River	Aug 14, 2024	LTD	LTD	LTD	0.60

Tap Water Quality for Public Water Supplies in Newfoundland  
and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
				Guidelines for Canadian Drinking Water Quality	7	10	1
Mary's Harbour	Mary's Harbour	St. Mary's River	Aug 14, 2024	0.01	LTD	LTD	9.00
Marystown	Marystown	Fox Hill Reservoir / Clam Pond	Sep 09, 2024	0.02	LTD	LTD	2.30
Marysvale	Marysvale, Long Pond	Drilled	Sep 23, 2024	0.02	LTD	LTD	0.65
Mattis Point	Mattis Point	Drilled	Sep 26, 2024	0.11	LTD	LTD	0.55
McCallum	McCallum	Drilled	Sep 25, 2024	0.05	LTD	LTD	25.00
Ming's Bight	Ming's Bight	Middle Brook Pond	Sep 05, 2024	0.01	LTD	LTD	5.40
Mount Pearl	Mount Pearl	Bay Bulls Big Pond	Sep 12, 2024	0.01	0.06	LTD	1.90
Nain	Nain	Trouser Lake	Aug 28, 2024	0.01	LTD	LTD	1.80
Natuashish	Natuashish (Sango Bay)	Sango Brook and Wellfield	Aug 29, 2024	0.07	0.07	LTD	1.20
New Harbour	New Harbour	Williams Hill Well	Aug 06, 2024	0.13	LTD	0.02	0.84
Norris Arm	Norris Arm (south)	Mill Lake	Aug 12, 2024	0.01	0.06	LTD	4.10
North West River	North West River	Wellfield (Well # 1 & Well # 2)	Aug 16, 2024	0.12	LTD	LTD	LTD
O'Donnells	O'Donnell's	Well Field	Aug 14, 2024	0.08	0.14	LTD	0.67
O'Regans East	O'Regan's East	Drilled	Sep 23, 2024	0.38	0.45	LTD	1.10
Paradise	Paradise	Bay Bulls Big Pond	Sep 12, 2024	0.01	0.06	LTD	1.70
Petley	Petley	Drilled + Dug Reservoir	Aug 28, 2024	0.03	LTD	LTD	6.50
Piccadilly Slant-Abraham's Cove	Piccadilly Slant	#1 Well - Piccadilly Slant	Sep 18, 2024	0.25	0.29	LTD	1.40
Piccadilly Slant-Abraham's Cove	Abraham's Cove	#2 Well - Abraham's Cove	Sep 19, 2024	0.14	2.60	LTD	2.50
Point Lance	Point Lance (5 houses)	Well	Sep 26, 2024	0.06	LTD	LTD	0.74
Point of Bay	Point of Bay	Indian Cove Pond	Aug 06, 2024	0.01	LTD	LTD	5.70
Pool's Cove	Pool's Cove	Widgeon Pond	Jul 04, 2024	0.02	LTD	LTD	8.00
Port Blandford	Port Blandford	Noseworthy's Pond	Aug 28, 2024	0.01	LTD	LTD	6.10
Port Hope Simpson	Port Hope Simpson	Arnold's Brook and Pond	Aug 15, 2024	0.00	LTD	LTD	9.50
Port Kirwan	Port Kirwan	Developed Spring	Aug 28, 2024	0.02	0.25	LTD	LTD
Port Kirwan	North Side	Dug Well / Drilled Well	Aug 28, 2024	0.05	0.05	LTD	0.60
Port Rexton	Port Rexton	#1 Well - Lois Long Well	Aug 29, 2024	0.11	0.46	LTD	LTD
Port Rexton	Port Rexton (Seasonal Use)	#2 Well - Edmund Brown's Well	Aug 29, 2024	0.09	0.54	LTD	1.30
Port Rexton	Ship Cove	#6 Well - Banister's Well	Aug 29, 2024	0.11	0.09	LTD	1.30
Port Rexton	Champneys Arm	Champney's Arm Well	Aug 29, 2024	0.19	LTD	LTD	2.60
Port au Port East	Port au Port East	Drilled Well - 75-80% Berry Head Watershed - 20-25%	Sep 04, 2024	0.06	0.13	LTD	3.30
Port au Port West-Aguathuna-Felix Cove	Port au Port West, Aguathuna	#1 & #3 & #6 FatherJoy's Well	Sep 16, 2024	0.34	0.07	LTD	2.00

Tap Water Quality for Public Water Supplies in Newfoundland  
and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
				Guidelines for Canadian Drinking Water Quality			
Port au Port West-Aguathuna-Felix Cove	Felix Cove	#4-Goose Pond Road Well	Sep 19, 2024	0.19	0.19	LTD	1.00
Port au Port West-Aguathuna-Felix Cove	Felix Cove	#5 Ocean View Drive Well	Sep 19, 2024	0.19	0.17	LTD	1.00
Portugal Cove-St. Phillips	Portugal Cove-St. Phillips	Bay Bulls Big Pond	Sep 12, 2024	0.02	0.06	LTD	1.60
Postville	Postville - PWDU	Big Pond	Aug 29, 2024	LTD	LTD	LTD	LTD
Postville	Postville	Big Pond	Aug 29, 2024	0.01	LTD	LTD	6.60
Pouch Cove	Pouch Cove	North Three Island Pond	Aug 16, 2024	0.00	LTD	LTD	LTD
Raleigh	Raleigh	#4 Well	Sep 11, 2024	0.20	LTD	LTD	2.00
Ramea	Ramea	Northwest Pond	Sep 26, 2024	0.03	LTD	LTD	3.80
Ramea	Ramea - PWDU	Northwest Pond	Sep 26, 2024	LTD	LTD	LTD	LTD
Random Sound West	North West Brook, Ivany Cove	#1 Well - Cabot Road South Well	Sep 25, 2024	0.80	LTD	LTD	2.10
Random Sound West	North West Brook, Ivany Cove	#2 Well	Sep 25, 2024	0.12	0.79	LTD	0.69
Red Bay	Red Bay	Northern Brook	Aug 14, 2024	0.01	LTD	LTD	8.00
Red Harbour	Red Harbour	1A Well Drilled + 1C Dug Well (back-up)	Sep 09, 2024	0.46	0.08	LTD	1.80
Reidville	Reidville	Humber Canal, Grand Lake	Aug 26, 2024	0.02	0.12	LTD	3.70
Renews-Cappahayden	Cappahayden	#1 Dinn's Well	Aug 29, 2024	0.30	LTD	LTD	0.63
Rigolet	Rigolet - PWDU	Rigolet Pond	Aug 29, 2024	LTD	LTD	LTD	LTD
Rigolet	Rigolet	Rigolet Pond	Aug 29, 2024	0.01	LTD	LTD	11.00
Riverhead	Riverhead (St. Mary's Bay)	Well Field	Aug 14, 2024	0.02	0.32	LTD	1.10
Sandringham	Sandringham	Drilled	Aug 05, 2024	0.03	0.44	LTD	0.83
Sandy Cove	Sandy Cove	Dug	Aug 05, 2024	0.03	0.33	LTD	0.53
Sheaves Cove	Sheaves Cove	Drilled	Sep 18, 2024	0.28	0.32	LTD	1.10
Sheppardville	Sheppardville	Drilled	Sep 04, 2024	0.06	LTD	LTD	3.30
Sheshatshiu	Sheshatshiu - Indian Band Council	Wells 1, 2 & 3	Aug 16, 2024	0.16	0.24	LTD	0.99
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#1 Well - PJ's Variety Well	Sep 19, 2024	0.36	0.09	LTD	1.40
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#2 Well - Howard & Rodney Jesso Well	Sep 19, 2024	0.27	0.22	LTD	1.80
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove East	#3 Well - Bernard Brake Well	Sep 19, 2024	0.26	0.52	LTD	1.70
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#4B Well - Nancy Rowe Well	Sep 18, 2024	1.00	0.06	LTD	1.90
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#5 Well - Murdock Wheeler Well	Sep 19, 2024	0.28	0.21	LTD	LTD
Ship Cove-Lower Cove-Jerry's Nose	Lower Cove	#6 Well - Lower Cove Well	Sep 18, 2024	0.20	0.39	LTD	0.56
Small Point-Adam's Cove-Blackhead-Broad Cove	Adam's Cove	#1 Well - Reg Bursey Well	Sep 24, 2024	0.34	0.26	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Blackhead + Adam's Cove	#4 Well - Leonard King Well	Sep 24, 2024	0.13	0.15	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland  
and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
				Guidelines for Canadian Drinking Water Quality			
Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#6 Well - Herb Trickett Well	Sep 24, 2024	0.14	0.14	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#8 Well - Effie Flight Wells	Sep 24, 2024	0.25	1.70	LTD	LTD
Smith's Sound	Harcourt-Monroe-Waterville	Developed Spring	Aug 28, 2024	0.11	0.05	LTD	1.60
South Dildo	South Dildo	#5 Well - Calvin Reid Well	Aug 06, 2024	0.09	LTD	LTD	0.73
Springdale	Springdale Industrial Park	Well	Sep 16, 2024	0.12	0.36	LTD	LTD
St. Alban's	St. Alban's	Well Field	Aug 14, 2024	0.02	0.33	LTD	LTD
St. Andrews	St. Andrew's	#1 Well	Sep 23, 2024	1.10	0.28	LTD	1.00
St. Andrews	St. Andrew's	#2 Well	Sep 23, 2024	0.36	LTD	LTD	1.80
St. Andrews	St. Andrew's East	#3 Well	Sep 25, 2024	0.28	0.15	LTD	1.20
St. Andrews	Air Strip Road	#4 Well Strip Road Well	Sep 23, 2024	0.70	LTD	LTD	0.78
St. Anthony	St. Anthony	St. Anthony Pond	Sep 11, 2024	0.01	0.07	LTD	6.60
St. George's	St. George's	Wellfield	Sep 26, 2024	0.11	0.19	LTD	1.70
St. John's	St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	Sep 19, 2024	0.01	LTD	0.01	1.70
St. John's	St. John's	Petty Harbour Long Pond	Sep 16, 2024	0.02	LTD	LTD	1.70
St. John's	St. John's	Windsor Lake	Sep 16, 2024	0.01	LTD	LTD	2.00
St. Joseph's	St. Joseph's S.M.B.	Drilled	Aug 14, 2024	0.12	LTD	LTD	3.40
St. Judes	St. Judes	Chute Brook	Jul 19, 2024	0.10	LTD	LTD	9.00
St. Judes	St. Judes	Chute Brook	Jul 19, 2024	0.09	0.05	LTD	9.20
St. Judes	St. Judes	Chute Brook	Jul 19, 2024	0.14	0.11	LTD	6.50
St. Lewis	St. Lewis	Tub Harbour Pond	Aug 14, 2024	0.01	LTD	LTD	10.00
St. Lunaire-Griquet	St. Lunaire-Griquet	Drilled	Sep 11, 2024	0.15	LTD	LTD	3.00
St. Mary's	St. Mary's	Wellfield	Aug 14, 2024	0.10	0.09	LTD	0.70
St. Patricks	St. Patricks	David Joy Well	Sep 16, 2024	0.07	LTD	LTD	LTD
St. Pauls	St. Pauls	Two Mile Pond	Sep 18, 2024	0.07	0.07	LTD	7.90
Steady Brook	Steady Brook	Wellfield + Steady Brook	Sep 18, 2024	0.42	0.07	LTD	4.50
Stephenville	Stephenville	Well Field	Sep 04, 2024	0.13	0.20	LTD	LTD
Stephenville Crossing	Stephenville Crossing	Well Fields 1 & 2	Sep 04, 2024	0.10	0.30	LTD	LTD
Sunnyside (T.B.)	Sunnyside	Center Cove River	Aug 09, 2024	0.01	LTD	LTD	7.00
Swift Current	Swift Current (Hollett's Point)	Drilled	Aug 14, 2024	0.05	LTD	LTD	7.30
Terrenceville	Terrenceville	Big Brook	Sep 12, 2024	0.00	LTD	LTD	15.00
Tompkins	Tompkins	Greg Wall Well	Sep 23, 2024	0.23	0.25	LTD	LTD
Upper Amherst Cove	Upper Amherst Cove	Drilled	Aug 06, 2024	0.13	LTD	LTD	2.50



**Tap Water Quality for Public Water Supplies in Newfoundland  
and Labrador - Additional Parameters**

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units	mg/L	mg/L	mg/L
				Guidelines for Canadian Drinking Water Quality	7	10	1
Upper Ferry	Upper Ferry - Lower	#1 Well - Gerard Brownrigg Well	Sep 23, 2024	0.39	0.69	LTD	LTD
Upper Ferry	Upper Ferry - Middle	#2 Well - Hughie MacIsaac Well	Sep 23, 2024	0.22	0.11	LTD	LTD
Upper Ferry	Upper Ferry - Upper	#3 Well - Marshall Devoe Well	Sep 23, 2024	0.27	0.12	LTD	LTD
Upper Ferry	Upper Ferry	#4 Well - Angus MacNeil Well	Sep 23, 2024	0.39	0.07	LTD	LTD
Wabana	Wabana	#3 Yard West Mines Road	Sep 17, 2024	0.68	LTD	LTD	5.90
Wabana	Wabana - PWDU	#3 Yard West Mines Road	Sep 17, 2024	LTD	LTD	LTD	LTD
Wabana	Wabana	#4-West Mines Road	Sep 17, 2024	0.36	LTD	LTD	4.70
Wabana	Wabana	Middleton Ave	Sep 17, 2024	0.39	LTD	LTD	3.90
Wabana	Wabana	Mixed Supplies	Sep 17, 2024	0.41	LTD	LTD	2.10
Wabana	Wabana	Mixed Supplies	Sep 17, 2024	0.42	LTD	LTD	2.10
Wabana	Wabana	Mixed Supplies	Sep 17, 2024	0.41	LTD	LTD	2.20
Wabana	Wabana	Normore Crescent East #1	Sep 17, 2024	0.79	LTD	LTD	4.40
Wabana	Wabana	Quigley's Line	Sep 17, 2024	0.72	LTD	LTD	3.80
Wabana	Wabana	Scotia #1	Sep 17, 2024	0.36	LTD	LTD	3.80
Wabana	Wabana	St. Edward's Memorial St.	Sep 17, 2024	0.06	LTD	LTD	LTD
Wabush	Wabush	Wahnahnish Lake	Jul 25, 2024	0.02	LTD	LTD	3.80
West St. Modeste	West St. Modeste	Well Field	Aug 14, 2024	0.01	LTD	LTD	4.70
Winterland	Winterland	Well Field	Sep 11, 2024	0.14	0.78	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland  
and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
		Guidelines for Canadian Drinking Water Quality		7	10	1	

Tap water samples are collected semi annually from drinking water faucets of one or more homes, public buildings, or businesses in your community. Tap or treated water quality is monitored to check its compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Tap water quality is also monitored so that water that is being consumed at the tap can be compared with the untreated source water quality. Any variations between source and tap water quality represents the effectiveness of the treatment and disinfection system, and the influences of the distribution system due to plumbing in local homes, public buildings, or businesses. The values for each parameter are as reported by the lab and verified by the department.

This report for tap water provides a brief discussion and interpretation of health related water quality parameters, if any, that exceed the acceptable limits as set out in the GCDWQ. Guidelines have not been developed for all the parameters listed in this report.

Contaminants are substances that are known or suspected to cause adverse effects on the health of some people when present in concentrations greater than the established Maximum Acceptable Concentrations (MACs) or the Interim Maximum Acceptable Concentrations (IMACs) of the GCDWQ. Each MAC has been derived to safeguard health assuming lifelong consumption of drinking water containing the substance at that concentration. IMACs are reviewed periodically as new information becomes available. Please consult your Medical Officer of Health for additional information on the health aspects on contaminants. Contaminant exceedances are highlighted in **red text** and enclosed in a box.

The reported information is for supplies selected for sampling and may not include all public water supplies.

## Contaminant Exceedances

**Strontium:** The maximum acceptable concentration for strontium is 7.0 mg/L. Strontium may enter drinking water from naturally occurring deposits or as a result of human activity, such as mining or other industries. High levels of this contaminant can cause adverse health effects for some people.

**Nitrate:** The maximum acceptable concentration for nitrate is 10 mg/L as nitrate-nitrogen. Nitrate is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

**Nitrite:** The maximum acceptable concentration for nitrite is 1 mg/L as nitrite-nitrogen. Nitrite is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

**LTD - Less Than Detection Limit** - The detection limit is the lowest concentration of a substance that can be determined using a particular test method and instrument. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

mg/L = milligrams per litre or parts per million

TOC = total organic carbon