

SECTION 820

STORAGE AND HANDLING OF FUELS AND OTHER HAZARDOUS, TOXIC, OR DANGEROUS MATERIAL

INDEX

- 820.01 STORAGE TANK REGISTRATION, INSPECTION, AND REMOVAL**
- 820.02 SPILL REPORTING & CLEANUP PROCEDURES**
- 820.03 FUEL STORAGE & HANDLING PROCEDURES**
- 820.04 EQUIPMENT SERVICING PROCEDURES**
- 820.05 USE OF HAZARDOUS TOXIC OR DANGEROUS MATERIAL**
- 820.06 REMOVAL OF STRUCTURAL STEEL PROTECTIVE COATINGS**

820.01 STORAGE TANK REGISTRATION, INSPECTION, AND REMOVAL

All storage tank systems must be registered under and in compliance with Newfoundland Regulation 58/03, The Storage and Handling of Gasoline and Associated Products Regulations, 2003 before commencing operation. Registration does not apply to storage tank systems of a capacity less than 2500 litres that are connected to a heating appliance. Contractors shall supply verification of storage tank registration to the Owner's representative prior to the commencement of work.

Storage tank systems shall be operated as per Section 18 of Newfoundland Regulation 58/03 Storage and Handling of Gasoline and Associated Products. This involves, but is not limited to, gauging or dipping, reconciliation of records and the proper maintenance of reconciliation records for a period of two years. Records shall be maintained for inspection by the Owner's representative and/or Government Service Centre Inspectors.

The operator of a storage tank system shall, within 30 days of known abandonment, empty the system of all products, remove the tank and associated piping from the ground, remove any contaminated soil, clean the area and restore the site to the satisfaction of the Owner's representative and in accordance with the criteria of the Government Services Centre.

820.02 SPILL REPORTING & CLEANUP PROCEDURES

The Contractor, Subcontractors, and their personnel shall take all necessary precautions to prevent the spillage, misplacement, or loss of fuels and other hazardous material.

The Contractor and Subcontractors shall abide by the following measures in the event of the detection of a fuel or hazardous material spill of 70 litres or more:

- a) make every effort to stop leakage and contain contaminant flow;
- b) immediately upon detection, report spill location and size to the Canadian Coast Guard spill report number 772-2083, Pesticides Control Section 729-3395 and to the Owner; follow up with a full written report containing information on the cause of the spill, remedial action taken, damage or contamination estimate, and any further action to be taken;
- c) remove contaminant from spill site by absorbent, pumping, burning, or whatever method is appropriate and acceptable to Owner. Clean-up the affected area in accordance with the requirements of the Government Services Centre and then dispose of contaminated debris at an accepted waste disposal site.
- d) take all necessary action to ensure the incident does not recur.

The Contractor shall apply the following criteria in reaching decisions on contaminant and clean-up procedures:

- a) minimize danger to persons;
- b) minimize pollution to watercourses and wetlands;
- c) minimize the size of the area affected by a spill; and
- d) minimize the degree of disturbance to the area and watercourses during clean-up and reported promptly to the Owner's representative.

The Contractor shall dispose of any soil contaminated by small leaks of oil or lubricating fluids from equipment in a manner accepted by the Owner's representative and in accordance with the criteria of the Government Services Centre. The Contractor shall have on site a suitable quantity of absorbent material such as "Oclansorb" or similar product which can be accessed quickly and effectively in the event of any hydrocarbon spill. The contractor shall advise fuel handling staff of its location and application.

820.03 FUEL STORAGE & HANDLING PROCEDURES

Contractor shall ensure that fuels and hazardous materials are handled only by personnel who are trained and qualified in handling these materials in accordance with manufacturers' instructions and government regulations. The Contractor will be required to verify personnel qualifications as they pertain to this item and provide written confirmation of same to the Owner's representative. The Contractor shall supply a copy of the product safety data sheet to the Owner's representative of all hazardous, toxic or dangerous materials or substances which will be used during the course of the contract.

Refueling operations shall be supervised at all times. Under no circumstances shall any refueling procedure be left unattended by the operator.

Handling and fueling procedures shall be carried out to prevent the contamination of soil or water. Smoking shall be prohibited within 10 m of a fuel storage area or during refueling operations. Fueling or servicing of mobile equipment shall not be allowed within 100 m of a watercourse, water body, or designated wetlands. Oils, greases, gasoline, diesel, hydraulic and transmission fluids or other fuels shall be stored at least 100m (horizontal distance) from any water course, water body, or designated wetland unless otherwise accepted by the Owner's representative.

Any above ground fuel containers, with the exception of those exempted under Newfoundland Regulation 58/03, shall be self dyked units that are in compliance with the terms and conditions of the approval of the Government Services Center. Fuel storage areas and non-portable transfer lines shall be clearly marked or barricaded to ensure that they are not damaged by moving vehicles. The markers shall be visible under all weather conditions. The storage, handling and disposal of used oils shall be in accordance with the Used Oil Control Regulations (82-02) under the NL Environmental Protection Act.

820.04 EQUIPMENT SERVICING PROCEDURES

All heavy equipment maintenance shall be carried out by using suitable fluid collection equipment and in a manner which ensures all waste material is collected and suitably disposed of. The Contractor shall ensure that all equipment is mechanically sound to avoid leaks of grease, oil, diesel, gasoline, and hydraulic and transmission fluids. The Contractor shall ensure that no servicing or washing of heavy equipment occurs adjacent to watercourses and designated wetlands. Fueling, servicing or washing of equipment shall not be allowed within 100 m of a watercourse except within a refueling site accepted by the Owner's representative where conditions allow for containment of accidentally spilled fuels. The Contractor shall remove from the work area and properly dispose of all waste oil, filters, containers or other such debris at an accepted waste disposal site.

820.05 USE OF HAZARDOUS TOXIC OR DANGEROUS MATERIAL

Toxic construction material e.g., creosote treated timber, shall be stored at least 100 m away from all areas where drainage is directed into any watercourse or wetlands.

Toxic or dangerous substances such as form release agents, fuels, concrete additives (including superplasticisers), and other such substances, shall be transported, stored, and handled with all necessary precautions so as to prevent any spillage from occurring. Drip pans shall be used at locations where such liquids are being drawn off in order to contain any minor spills, and as a safety measure for containment of a significant spillage.

820.06 REMOVAL OF STRUCTURAL STEEL PROTECTIVE COATINGS

Solid waste produced by the removal of steel protective coatings is not permitted to be released into any watercourse or water body or into any ditch or area that leads directly to a watercourse or water body. The specifications in **825.03** are intended to provide guidance to individuals involved in the removal of structural steel protective coatings with respect to the minimum acceptable control measures and the appropriate disposal procedures for the generated solid waste.