



NOTES:

1. THIS DETAIL IS INTENDED TO SHOW TYPICAL DIMENSIONS FOR PAYMENT PURPOSES ONLY. ACTUAL TRENCH DIMENSIONS ARE SUBJECT TO FIELD CONDITIONS AND/OR THE REQUIREMENTS OF THE HEALTH AND SAFETY REGULATIONS.

DEPTH	MIN WIDTH
0-4m	1500mm
>4m, <6m	2000mm
>6m	2500mm
2. BEDDING TYPE SHALL BE AS SPECIFIED IN THE CONTRACT DOCUMENTS REQUIRED SCHEDULE OF QUANTITIES AND PRICES.
3. UNDER NO CIRCUMSTANCES, SHALL ANY SANITARY OR STORM SEWER BE INSTALLED AT ZERO SLOPE.
4. MAINTAIN MINIMUM HORIZONTAL SEPARATION BETWEEN SEWER AND WATER MAIN OF 3000mm. WHERE MINIMUM HORIZONTAL SEPARATION IS NOT ACHIEVABLE, MAINTAIN MINIMUM VERTICAL SEPARATION OF 450mm FROM CROWN OF SEWERMAIN TO UNDERSIDE OF WATER MAIN.
5. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE NOTED.

MUNICIPAL MASTER
SPECIFICATIONS

TYPICAL TRENCH DETAIL - MULTIPLE PIPES

DRAWING NUMBER 04040

DATE: APRIL 2023
SCALE: N.T.S.