



NOTES:

1. WHEN CATCH BASINS ARE PLACED BACK TO BACK ON BOTH SIDES OF THE CONCRETE BARRIER, BACKFILL SHALL BE UNSHRINKABLE BACKFILL TO THE LIMITS OF EXCAVATION AND WITHIN 150mm OF TOP OF CONCRETE CATCH BASIN STRUCTURE. WHERE CATCH BASINS ARE NOT PLACED BACK TO BACK THEY SHALL BE STAGGERED WITH A MINIMUM SPACING OF 10m.
2. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE NOTED.

**MUNICIPAL MASTER
SPECIFICATIONS**

**CATCH BASIN FRAME WITH GRATE SHOULDER
INSTALLATION AT CONCRETE BARRIER**

DRAWING NUMBER 04440

DATE: APRIL 2023
SCALE: N.T.S.